

Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

S-13

Lab# 149

Sample Collection Customer Facility Name: Hilton Garden Inn Date: 6/2/25 Time: 1:35 PM Address: Method: Synergy Dr. Grab Uniontown, PA 15401 Sample Final Analysis Matrix: Recreational Water Date: 6/5/25 Time: 9:30 AM Source Type: Spa Analyst: AS **Accredited Analysis Reporting limit** Results **Analyst** Method **Incubation Date/Time** Escherichia Coli: Absent 6/3/25 10:00 AM EΒ SM 9222G Absent Total coliforms: 0/100mls 2/100mls 6/3/25 10:00 AM EΒ SM 9222B SL Standard plate count: 0/ml 200/ml 6/2/25 5:40 PM SM 9215B **Additional Analysis** Reporting limit Results Incubation Date/Time **Analyst** Method Fecal Streptococcus 0/100mls 2/100mls 6/3/25 11:30 AM AΗ SM 9230C **Field Analysis** Results **Reporting limit** Date/Time **Analyst** Method pH: 7.4 SU 7.2 - 7.8 SU 6/2/25 1:35 PM SH DPD Chlorine: DPD 3.0 mg/l 1.0 - 5.0 mg/l 6/2/25 1:35 PM SH

6/2/25

1 - 2 NTU

Sample comments

Turbidity:

andre Smith

1:35 PM

SH

Visual

(When exceeding reporting limit pool or spa is unfit)

1 NTU



Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

S-13

Lab# 149

Sample Collection Customer Facility Name: Hilton Garden Inn Date: 6/2/25 Time: 1:35 PM Address: Method: Synergy Dr. Grab Uniontown, PA 15401 Sample Final Analysis Matrix: Recreational Water Date: 6/5/25 Time: 9:30 AM Source Type: Spa Analyst: AS **Accredited Analysis Reporting limit** Results **Analyst** Method **Incubation Date/Time** Escherichia Coli: Absent 6/3/25 10:00 AM EΒ SM 9222G Absent Total coliforms: 0/100mls 2/100mls 6/3/25 10:00 AM EΒ SM 9222B SL Standard plate count: 0/ml 200/ml 6/2/25 5:40 PM SM 9215B **Additional Analysis** Reporting limit Results Incubation Date/Time **Analyst** Method Fecal Streptococcus 0/100mls 2/100mls 6/3/25 11:30 AM AΗ SM 9230C **Field Analysis** Results **Reporting limit** Date/Time **Analyst** Method pH: 7.4 SU 7.2 - 7.8 SU 6/2/25 1:35 PM SH DPD Chlorine: DPD 3.0 mg/l 1.0 - 5.0 mg/l 6/2/25 1:35 PM SH

6/2/25

1 - 2 NTU

Sample comments

Turbidity:

andre Smith

1:35 PM

SH

Visual

(When exceeding reporting limit pool or spa is unfit)

1 NTU