



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 10

Lab# 224

Customer

Facility Name: McKeesport H.S.
Address: 1960 Eden Park Blvd.
McKeesport, PA 15132

Matrix: Recreational Water

Source Type: Shallow End

Sample Collection

Date: 5/29/25
Time: 10:45 AM
Method: Grab

Sample Final Analysis

Date: 5/31/25
Time: 3:30 PM
Analyst: AS

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|-----------------------|----------|-----------------|----------------------|---------|---------|----------|
| Escherichia Coli: | Absent | Absent | 5/29/25 | 6:05 PM | SL | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 5/29/25 | 6:05 PM | SL | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 5/29/25 | 6:05 PM | SL | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|----------------|----------|-----------------|-----------|----------|---------|--------|
| pH: | 8.0 SU | 7.2 - 7.8 SU | 5/29/25 | 10:45 AM | BH | DPD |
| Chlorine: | 2.0 mg/l | 1.0 - 5.0 mg/l | 5/29/25 | 10:45 AM | BH | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 5/29/25 | 10:45 AM | BH | Visual |

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 10

Lab# 224

Customer

Facility Name: McKeesport H.S.
Address: 1960 Eden Park Blvd.
McKeesport, PA 15132

Matrix: Recreational Water
Source Type: Shallow End

Sample Collection

Date: 5/29/25
Time: 10:45 AM
Method: Grab

Sample Final Analysis

Date: 5/31/25
Time: 3:30 PM
Analyst: AS

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|-----------------------|----------|-----------------|----------------------|---------|---------|----------|
| Escherichia Coli: | Absent | Absent | 5/29/25 | 6:05 PM | SL | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 5/29/25 | 6:05 PM | SL | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 5/29/25 | 6:05 PM | SL | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|----------------|----------|-----------------|-----------|----------|---------|--------|
| pH: | 8.0 SU | 7.2 - 7.8 SU | 5/29/25 | 10:45 AM | BH | DPD |
| Chlorine: | 2.0 mg/l | 1.0 - 5.0 mg/l | 5/29/25 | 10:45 AM | BH | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 5/29/25 | 10:45 AM | BH | Visual |

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor