



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 10

Lab# 460

Customer

Facility Name: Wilmerding Center

Address: 1 Memorial Field
Wilmerding, PA 15148

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 7/9/25

Time: 10:30 AM

Method: Grab

Sample Final Analysis

Date: 7/12/25

Time: 8:30 AM

Analyst: AS

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|-----------------------|----------|-----------------|----------------------|----------|---------|----------|
| Escherichia Coli: | Absent | Absent | 7/10/25 | 10:50 AM | SL | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 7/10/25 | 10:50 AM | SL | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 7/9/25 | 6:15 PM | SL | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|----------------|----------|-----------------|-----------|----------|---------|--------|
| pH: | 7.6 SU | 7.2 - 7.8 SU | 7/9/25 | 10:30 AM | BH | DPD |
| Chlorine: | 3.0 mg/l | 1.0 - 5.0 mg/l | 7/9/25 | 10:30 AM | BH | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 7/9/25 | 10:30 AM | BH | Visual |

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 10

Lab# 460

Customer

Facility Name: Wilmerding Center

Address: 1 Memorial Field
Wilmerding, PA 15148

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 7/9/25

Time: 10:30 AM

Method: Grab

Sample Final Analysis

Date: 7/12/25

Time: 8:30 AM

Analyst: AS

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|-----------------------|----------|-----------------|----------------------|----------|---------|----------|
| Escherichia Coli: | Absent | Absent | 7/10/25 | 10:50 AM | SL | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 7/10/25 | 10:50 AM | SL | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 7/9/25 | 6:15 PM | SL | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|----------------|----------|-----------------|-----------|----------|---------|--------|
| pH: | 7.6 SU | 7.2 - 7.8 SU | 7/9/25 | 10:30 AM | BH | DPD |
| Chlorine: | 3.0 mg/l | 1.0 - 5.0 mg/l | 7/9/25 | 10:30 AM | BH | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 7/9/25 | 10:30 AM | BH | Visual |

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor