



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-10

Lab# 2201

Customer

Facility Name: Fox Chapel Golf Club
Address: 426 Fox Chapel Road
Pittsburgh, PA 15238-2298

Matrix: Recreational Water

Source Type: Shallow End

Sample Collection

Date: 6/3/25
Time: 12:30 PM
Method: Grab

Sample Final Analysis

Date: 6/6/25
Time: 9:30 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/4/25	11:00 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/4/25	11:00 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	6/3/25	4:45 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	6/3/25	12:30 PM	BH	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	6/3/25	12:30 PM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/3/25	12:30 PM	BH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-10

Lab# 2201

Customer

Facility Name: Fox Chapel Golf Club
Address: 426 Fox Chapel Road
Pittsburgh, PA 15238-2298

Matrix: Recreational Water

Source Type: Shallow End

Sample Collection

Date: 6/3/25
Time: 12:30 PM
Method: Grab

Sample Final Analysis

Date: 6/6/25
Time: 9:30 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/4/25	11:00 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/4/25	11:00 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	6/3/25	4:45 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	6/3/25	12:30 PM	BH	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	6/3/25	12:30 PM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/3/25	12:30 PM	BH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor