



Lab ID No. 02-04041

Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Service**Lab# 312****Customer****Facility Name:** UPMC Lemieux Sports Complex**Address:** 8000 Cranberry Springs Drive
Cranberry Township, PA 16066**Matrix:** Recreational Water**Source Type:** Cold Plunge**Sample Collection****Date:** 10/28/25**Time:** 10:45 AM**Method:** Grab**Sample Final Analysis****Date:** 10/31/25**Time:** 11:00 AM**Analyst:** AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	10/29/25	10:30 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	10/29/25	10:30 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	10/28/25	4:30 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	10/28/25	10:45 AM	JR	DPD
Chlorine:	4.8 mg/l	1.0 - 5.0 mg/l	10/28/25	10:45 AM	JR	DPD
Turbidity:	1 NTU	1 - 2 NTU	10/28/25	10:45 AM	JR	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor