



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-12

Lab# 2494

Customer

Facility Name: South Hills Country Club

Address: 4305 Brownsville Road
Pittsburgh, PA 15236

Matrix: Recreational Water

Source Type: Deep End

Sample Collection

Date: 7/14/25

Time: 12:45 PM

Method: Grab

Sample Final Analysis

Date: 7/17/25

Time: 8:30 AM

Analyst: AS

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|-----------------------|----------|-----------------|----------------------|----------|---------|----------|
| Escherichia Coli: | Absent | Absent | 7/15/25 | 10:15 AM | AH | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 7/15/25 | 10:15 AM | AH | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 7/14/25 | 5:00 PM | AH | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|----------------|----------|-----------------|-----------|----------|---------|--------|
| pH: | 7.4 SU | 7.2 - 7.8 SU | 7/14/25 | 12:45 PM | SL | DPD |
| Chlorine: | 3.0 mg/l | 1.0 - 5.0 mg/l | 7/14/25 | 12:45 PM | SL | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 7/14/25 | 12:45 PM | SL | Visual |

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-12

Lab# 2494

Customer

Facility Name: South Hills Country Club

Address: 4305 Brownsville Road
Pittsburgh, PA 15236

Matrix: Recreational Water

Source Type: Deep End

Sample Collection

Date: 7/14/25

Time: 12:45 PM

Method: Grab

Sample Final Analysis

Date: 7/17/25

Time: 8:30 AM

Analyst: AS

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|-----------------------|----------|-----------------|----------------------|----------|---------|----------|
| Escherichia Coli: | Absent | Absent | 7/15/25 | 10:15 AM | AH | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 7/15/25 | 10:15 AM | AH | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 7/14/25 | 5:00 PM | AH | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|----------------|----------|-----------------|-----------|----------|---------|--------|
| pH: | 7.4 SU | 7.2 - 7.8 SU | 7/14/25 | 12:45 PM | SL | DPD |
| Chlorine: | 3.0 mg/l | 1.0 - 5.0 mg/l | 7/14/25 | 12:45 PM | SL | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 7/14/25 | 12:45 PM | SL | Visual |

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor