



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661-7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-16

Lab# 2511

Customer

Facility Name: Stone Creek Apts.

Address: 1 Clubhouse Circle
Washington, PA 15301

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 6/11/25

Time: 12:28 PM

Method: Grab

Sample Final Analysis

Date: 6/13/25

Time: 3:00 PM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	6/11/25	5:30 PM	SL SM 9222G
Total coliforms:	0/100mls	2/100mls	6/11/25	5:30 PM	SL SM 9222B
Standard plate count:	0/ml	200/ml	6/11/25	5:30 PM	AS SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	6/11/25	12:28 PM	CW DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	6/11/25	12:28 PM	CW DPD
Turbidity:	1 NTU	1 - 2 NTU	6/11/25	12:28 PM	CW Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

A handwritten signature in black ink that reads "Andre Smith".

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661-7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-16

Lab# 2511

Customer

Facility Name: Stone Creek Apts.

Address: 1 Clubhouse Circle
Washington, PA 15301

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 6/11/25

Time: 12:28 PM

Method: Grab

Sample Final Analysis

Date: 6/13/25

Time: 3:00 PM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	6/11/25	5:30 PM	SL SM 9222G
Total coliforms:	0/100mls	2/100mls	6/11/25	5:30 PM	SL SM 9222B
Standard plate count:	0/ml	200/ml	6/11/25	5:30 PM	AS SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	6/11/25	12:28 PM	CW DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	6/11/25	12:28 PM	CW DPD
Turbidity:	1 NTU	1 - 2 NTU	6/11/25	12:28 PM	CW Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

A handwritten signature in black ink that reads "Andre Smith".

Andre Smith, Lead Supervisor