

**Dream Pools and Spas  
1105 Washington Blvd  
Pittsburgh, Pennsylvania 15206  
(412) 661- 7665  
Laboratory Analysis Report**

Lab ID No. 02-04041

C-10

Lab# 261

**Customer**

Facility Name: Rehabilitation Institute

**Sample Collection**

Date: 5/27/25

Address: 1405 Shady Ave.  
Pittsburgh, PA 15217

Time: 9:20 AM

Method: Grab

Matrix: Recreational Water

**Sample Final Analysis**

Date: 5/30/25

Source Type: Pool - Lg

Time: 9:00 AM

Analyst: AS


Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	5/28/25	9:45 AM	AH SM 9222G
Total coliforms:	0/100mls	2/100mls	5/28/25	9:45 AM	AH SM 9222B
Standard plate count:	0/ml	200/ml	5/27/25	4:20 PM	EB SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	5/27/25	9:20 AM	LM DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	5/27/25	9:20 AM	LM DPD
Turbidity:	1 NTU	1 - 2 NTU	5/27/25	9:20 AM	LM Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

*Anne Smith*



**Dream Pools and Spas  
1105 Washington Blvd  
Pittsburgh, Pennsylvania 15206  
(412) 661- 7665  
Laboratory Analysis Report**

Lab ID No. 02-04041

C-10

Lab# 261

**Customer**

Facility Name: Rehabilitation Institute

**Sample Collection**

Date: 5/27/25

Address: 1405 Shady Ave.  
Pittsburgh, PA 15217

Time: 9:20 AM

Method: Grab

Matrix: Recreational Water

**Sample Final Analysis**

Date: 5/30/25

Source Type: Pool - Lg

Time: 9:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	5/28/25	9:45 AM	AH SM 9222G
Total coliforms:	0/100mls	2/100mls	5/28/25	9:45 AM	AH SM 9222B
Standard plate count:	0/ml	200/ml	5/27/25	4:20 PM	EB SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	5/27/25	9:20 AM	LM DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	5/27/25	9:20 AM	LM DPD
Turbidity:	1 NTU	1 - 2 NTU	5/27/25	9:20 AM	LM Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

*Anne Smith*