



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-2

Lab# 267

Customer

Facility Name: Ringold High School
Address: 1 Ram Drive
Monongahela, PA 15063

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 12/22/25
Time: 2:30 PM
Method: Grab

Sample Final Analysis

Date: 12/25/25
Time: 11:30 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/23/25	11:00 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/23/25	11:00 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	12/22/25	5:20 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	12/22/25	2:30 PM	SH	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	12/22/25	2:30 PM	SH	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/22/25	2:30 PM	SH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor