



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

C-2

Lab# 090

Customer

Facility Name: Doubletree Hotel
Address: Bigelow Square
Pittsburgh, PA 15219

Sample Collection

Date: 10/28/25
Time: 11:10 AM
Method: Grab

Sample Final Analysis

Date: 10/31/25
Time: 10:30 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	10/29/25	10:00 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	10/29/25	10:00 AM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	10/28/25	4:30 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	10/28/25	11:10 AM	BH DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	10/28/25	11:10 AM	BH DPD
Turbidity:	1 NTU	1 - 2 NTU	10/28/25	11:10 AM	BH Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor