



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 10

Lab# 2363

Customer

Facility Name: Mount Vernon Apts
Address: 2300 Surrey Lane
McKeesport, PA 15135

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 8/26/25
Time: 1:00 PM
Method: Grab

Sample Final Analysis

Date: 8/29/25
Time: 10:30 AM
Analyst: AS

| Accredited Analysis | Results | Reporting limit | Incubation | Date/Time | Analyst | Method |
|-----------------------|----------|-----------------|------------|-----------|---------|----------|
| Escherichia Coli: | Absent | Absent | 8/27/25 | 9:30 AM | AS | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 8/27/25 | 9:30 AM | AS | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 8/26/25 | 4:30 PM | AS | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | Analyst | Method | |
|----------------|----------|-----------------|-----------|---------|--------|--------|
| pH: | 7.4 SU | 7.2 - 7.8 SU | 8/26/25 | 1:00 PM | JC | DPD |
| Chlorine: | 5.0 mg/l | 1.0 - 5.0 mg/l | 8/26/25 | 1:00 PM | JC | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 8/26/25 | 1:00 PM | JC | Visual |

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor