Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-17

Lab#   436

Customer

			Sample Collection	
Facility Name:	*Grove City College*		*Date:*	*6/30/25*
			Time:	*3:15 PM*
Address:	*100 Campus Dr.*		*Method:*	*Grab*
	Grove City, PA 16127			
			Sample Final Analysis	
Matrix:	*Recreational Water*		*Date:*	*7/3/25*
			Time:	*9:30 AM*
Source Type:	*Comp Pool*		*Analyst:*	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/1/25	11:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/1/25	11:00 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/30/25	6:00 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	6/30/25	3:15 PM	BH	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	6/30/25	3:15 PM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/30/25	3:15 PM	BH	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor

Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Customer			*Sample Collection*	
Facility Name:	*Grove City College*		*Date:*	*6/30/25*
			Time:	3:15 PM
Address:	*100 Campus Dr.*		*Method:*	*Grab*
	Grove City, PA 16127			
			Sample Final Analysis	
Matrix:	*Recreational Water*		*Date:*	*7/3/25*
			Time:	*9:30 AM*
Source Type:	*Comp Pool*		*Analyst:*	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/1/25	11:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/1/25	11:00 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/30/25	6:00 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	6/30/25	3:15 PM	BH	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	6/30/25	3:15 PM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/30/25	3:15 PM	BH	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor