



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-2

Lab# 360

Customer

Facility Name: YMCA - Mon-Valley

Address: 101 Taylor Run Road
Monongahela, PA 15063

Matrix: Recreational Water

Source Type: Spa

Sample Collection

Date: 10/20/25

Time: 2:55 PM

Method: Grab

Sample Final Analysis

Date: 10/23/25

Time: 10:00 AM

Analyst: AS

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | Analyst | Method |
|---------------------|---------|-----------------|----------------------|---------|--------|
|---------------------|---------|-----------------|----------------------|---------|--------|

| | | | | | |
|-------------------|--------|--------|------------------|----|----------|
| Escherichia Coli: | Absent | Absent | 10/21/25 9:30 AM | SL | SM 9222G |
|-------------------|--------|--------|------------------|----|----------|

| | | | | | |
|------------------|----------|----------|------------------|----|----------|
| Total coliforms: | 0/100mls | 2/100mls | 10/21/25 9:30 AM | SL | SM 9222B |
|------------------|----------|----------|------------------|----|----------|

| | | | | | |
|-----------------------|------|--------|------------------|----|----------|
| Standard plate count: | 0/ml | 200/ml | 10/20/25 4:30 PM | SL | SM 9215B |
|-----------------------|------|--------|------------------|----|----------|

| Additional Analysis | Results | Reporting limit | Incubation Date/Time | Analyst | Method |
|---------------------|---------|-----------------|----------------------|---------|--------|
|---------------------|---------|-----------------|----------------------|---------|--------|

| | | | | | |
|---------------------|----------|----------|-------------------|----|----------|
| Fecal Streptococcus | 0/100mls | 2/100mls | 10/21/25 10:30 AM | JC | SM 9230C |
|---------------------|----------|----------|-------------------|----|----------|

| Field Analysis | Results | Reporting limit | Date/Time | Analyst | Method |
|----------------|---------|-----------------|-----------|---------|--------|
|----------------|---------|-----------------|-----------|---------|--------|

| | | | | | |
|-----|--------|--------------|------------------|----|-----|
| pH: | 7.4 SU | 7.2 - 7.8 SU | 10/20/25 2:55 PM | SH | DPD |
|-----|--------|--------------|------------------|----|-----|

| | | | | | |
|-----------|----------|----------------|------------------|----|-----|
| Chlorine: | 3.0 mg/l | 1.0 - 5.0 mg/l | 10/20/25 2:55 PM | SH | DPD |
|-----------|----------|----------------|------------------|----|-----|

| | | | | | |
|------------|-------|-----------|------------------|----|--------|
| Turbidity: | 1 NTU | 1 - 2 NTU | 10/20/25 2:55 PM | SH | Visual |
|------------|-------|-----------|------------------|----|--------|

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor