



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 3

Lab# 2738

Customer American Pools Management
3261 Babcock Blvd.
Pittsburgh, PA 15237

		<u>Sample Collection</u>
Facility Name:	South Fayette Twp	Date: 7/21/25
Address:	288 Recreation Rd. Bridgeville, PA 15017	Time: 1:39 PM Method: Grab
Matrix:	Recreational Water	<u>Sample Final Analysis</u>
Source Type:	Spray Pad	Date: 7/24/25 Time: 10:00 AM Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	7/22/25	11:30 AM	SL SM 9222G
Total coliforms:	0/100mls	2/100mls	7/22/25	11:30 AM	SL SM 9222B
Standard plate count:	0/ml	200/ml	7/21/25	5:30 PM	SL SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	7/21/25	1:39 PM	AF DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	7/21/25	1:39 PM	AF DPD
Turbidity:	1 NTU	1 - 2 NTU	7/21/25	1:39 PM	AF Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 3

Lab# 2738

Customer American Pools Management
3261 Babcock Blvd.
Pittsburgh, PA 15237

		<u>Sample Collection</u>
Facility Name:	South Fayette Twp	Date: 7/21/25
Address:	288 Recreation Rd. Bridgeville, PA 15017	Time: 1:39 PM Method: Grab
Matrix:	Recreational Water	<u>Sample Final Analysis</u>
Source Type:	Spray Pad	Date: 7/24/25 Time: 10:00 AM Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	7/22/25	11:30 AM	SL SM 9222G
Total coliforms:	0/100mls	2/100mls	7/22/25	11:30 AM	SL SM 9222B
Standard plate count:	0/ml	200/ml	7/21/25	5:30 PM	SL SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	7/21/25	1:39 PM	AF DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	7/21/25	1:39 PM	AF DPD
Turbidity:	1 NTU	1 - 2 NTU	7/21/25	1:39 PM	AF Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor