



1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

W-13

Lab# 330

Customer

Facility Name: West Allegheny H.S.
Address: 205 West Allegheny Road
Imperial, PA 15126

Sample Collection

Date: 5/28/25
Time: 9:57 AM
Method: Grab

Matrix: Recreational Water
Source Type: Shallow End

Sample Final Analysis

Date: 5/31/25
Time: 9:30 AM
Analyst: AS

| Accredited Analysis | Results | Reporting limit | Incubation | Date/Time | Analyst | Method |
|-----------------------|----------|-----------------|------------|-----------|---------|----------|
| Escherichia Coli: | Absent | Absent | 5/29/25 | 10:40 AM | AH | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 5/29/25 | 10:40 AM | AH | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 5/28/25 | 6:25 PM | SL | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | Analyst | Method | |
|----------------|----------|-----------------|-----------|---------|--------|--------|
| pH: | 7.6 SU | 7.2 - 7.8 SU | 5/28/25 | 9:57 AM | AH | DPD |
| Chlorine: | 2.0 mg/l | 1.0 - 5.0 mg/l | 5/28/25 | 9:57 AM | AH | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 5/28/25 | 9:57 AM | AH | Visual |

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

W-13

Lab# 330

Customer

Facility Name: West Allegheny H.S.
Address: 205 West Allegheny Road
Imperial, PA 15126

Sample Collection

Date: 5/28/25
Time: 9:57 AM
Method: Grab

Matrix: Recreational Water
Source Type: Shallow End

Sample Final Analysis

Date: 5/31/25
Time: 9:30 AM
Analyst: AS

| Accredited Analysis | Results | Reporting limit | Incubation | Date/Time | Analyst | Method |
|-----------------------|----------|-----------------|------------|-----------|---------|----------|
| Escherichia Coli: | Absent | Absent | 5/29/25 | 10:40 AM | AH | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 5/29/25 | 10:40 AM | AH | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 5/28/25 | 6:25 PM | SL | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | Analyst | Method | |
|----------------|----------|-----------------|-----------|---------|--------|--------|
| pH: | 7.6 SU | 7.2 - 7.8 SU | 5/28/25 | 9:57 AM | AH | DPD |
| Chlorine: | 2.0 mg/l | 1.0 - 5.0 mg/l | 5/28/25 | 9:57 AM | AH | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 5/28/25 | 9:57 AM | AH | Visual |

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor