Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 1

Lab# 2037

Customer	*American Pools Management*
	3261 Babcock Blvd.
	Pittsburgh, PA 15237

		Sample Collection	
Facility Name:	*Belmont Ridge*	*Date:*	*7/21/25*
		Time:	*7:43 AM*
Address:	*1100 Belmont Blvd.*	*Method:*	*Grab*
	Monroeville, PA 15146		
		Sample Final Analysis	
Matrix:	*Recreational Water*	*Date:*	*7/24/25*
		Time:	*10:00 AM*
Source Type:	*Pool*	*Analyst:*	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/22/25	9:00 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/22/25	9:00 AM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	7/21/25	3:07 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	7/21/25	7:43 AM	EH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	7/21/25	7:43 AM	EH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/21/25	7:43 AM	EH	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

_____

Andre Smith, Lead Supervisor

Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 1

Lab# 2037

Customer

American Pools Management
3261 Babcock Blvd.
Pittsburgh, PA 15237

Facility Name: *Belmont Ridge*

Address: *1100 Belmont Blvd.*
Monroeville, PA 15146

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Collection
Date: *7/21/25*
Time: *7:43 AM*
Method: *Grab*

Sample Final Analysis
Date: *7/24/25*
Time: *10:00 AM*
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/22/25	9:00 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/22/25	9:00 AM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	7/21/25	3:07 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	7/21/25	7:43 AM	EH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	7/21/25	7:43 AM	EH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/21/25	7:43 AM	EH	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

_____
Andre Smith, Lead Supervisor