



Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 2

Lab# 2227

Customer

American Pools Management
3261 Babcock Blvd.
Pittsburgh, PA 15237

Sample Collection

Facility Name: Glenmoor Farms

Date: 7/14/25

Address: 199 Rose Circle
Gibsonia, PA 15044

Time: 11:15 AM

Method: Grab

Matrix: Recreational Water

Sample Final Analysis

Date: 7/17/25

Time: 8:30 AM

Source Type: Pool

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/15/25	9:30 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/15/25	9:30 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	7/14/25	3:43 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	7/14/25	11:15 AM	GR	DPD
Chlorine:	7.5 mg/l	1.0 - 5.0 mg/l	7/14/25	11:15 AM	GR	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/14/25	11:15 AM	GR	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 2

Lab# 2227

Customer

American Pools Management
3261 Babcock Blvd.
Pittsburgh, PA 15237

Sample Collection

Facility Name: Glenmoor Farms

Date: 7/14/25

Address: 199 Rose Circle
Gibsonia, PA 15044

Time: 11:15 AM

Method: Grab

Matrix: Recreational Water

Sample Final Analysis

Date: 7/17/25

Time: 8:30 AM

Source Type: Pool

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/15/25	9:30 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/15/25	9:30 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	7/14/25	3:43 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	7/14/25	11:15 AM	GR	DPD
Chlorine:	7.5 mg/l	1.0 - 5.0 mg/l	7/14/25	11:15 AM	GR	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/14/25	11:15 AM	GR	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor