



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

C-1

Lab# 188

Customer

Facility Name: Jewish Community Cntr

Address: 5738 Forbes Ave.
Pittsburgh, PA 15217

Matrix: Recreational Water

Source Type: Small Pool

Sample Collection

Date: 12/9/25

Time: 8:56 AM

Method: Grab

Sample Final Analysis

Date: 12/12/25

Time: 9:30 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/10/25	9:00 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/10/25	9:00 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	12/9/25	5:00 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	12/9/25	8:56 AM	GR	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	12/9/25	8:56 AM	GR	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/9/25	8:56 AM	GR	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor