

Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

E - 11

Lab# 272

<u>Customer</u> <u>Sample Collection</u>

Facility Name: Seven Springs Resort Date: 8/4/25

Address: 777 Waterwheel Dr. Seven Spring: Method: Grab

Champion, PA 15622

Matrix: Recreational Water Sample Final Analysis

Date: 8/7

Recreational Water Date: 8/7/25 Time: 11:20 AM

Source Type: Pool Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation D	ate/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	8/5/25	10:50 AM	АН	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/5/25	10:50 AM	АН	SM 9222B
Standard plate count:	0/ml	200/ml	8/4/25	4:21 PM	АН	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	8/4/25	11:27 AM	JC	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	8/4/25	11:27 AM	JC	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/4/25	11:27 AM	JC	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor

andre Smith



Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

E - 11

Lab# 272

<u>Customer</u> <u>Sample Collection</u>

Facility Name: Seven Springs Resort Date: 8/4/25

Address: 777 Waterwheel Dr. Seven Spring: Method: Grab

Champion, PA 15622

Matrix: Recreational Water Sample Final Analysis

Date: 8/7

Recreational Water Date: 8/7/25 Time: 11:20 AM

Source Type: Pool Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation D	ate/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	8/5/25	10:50 AM	АН	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/5/25	10:50 AM	АН	SM 9222B
Standard plate count:	0/ml	200/ml	8/4/25	4:21 PM	АН	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	8/4/25	11:27 AM	JC	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	8/4/25	11:27 AM	JC	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/4/25	11:27 AM	JC	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor

andre Smith