



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-3

Lab# 323

Customer

Facility Name: Valley High School
Address: 703 Stevenson Blvd.
New Kensington, PA 15068

Sample Collection

Date: 9/23/25
Time: 1:09 PM
Method: Grab

Matrix: Recreational Water
Source Type: Pool

Sample Final Analysis

Date: 9/26/25
Time: 10:00 AM
Analyst: AS

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|-----------------------|----------|-----------------|----------------------|---------|---------|----------|
| Escherichia Coli: | Absent | Absent | 9/24/25 | 9:40 AM | SL | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 9/24/25 | 9:40 AM | SL | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 9/23/25 | 6:00 PM | AS | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|----------------|----------|-----------------|-----------|---------|---------|--------|
| pH: | 8.0 SU | 7.2 - 7.8 SU | 9/23/25 | 1:09 PM | AMH | DPD |
| Chlorine: | 3.0 mg/l | 1.0 - 5.0 mg/l | 9/23/25 | 1:09 PM | AMH | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 9/23/25 | 1:09 PM | AMH | Visual |

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor