



Lab ID No. 02-04041

Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Service**Lab# 340****Customer**

Facility Name: Winchester Apts
Address: 540 N. Neville St.
Pittsburgh, PA 15213
Matrix: Recreational Water
Source Type: Pool

Sample Collection

Date: 1/5/26
Time: 9:18 AM
Method: Grab

Sample Final Analysis

Date: 1/8/26
Time: 10:30 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	1/6/26	10:00 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	1/6/26	10:00 AM	JC	SM 9222B
Standard plate count:	570/ml	200/ml	1/5/26	5:00 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	1/5/26	9:18 AM	RD	DPD
Chlorine:	0.4 mg/l	1.0 - 5.0 mg/l	1/5/26	9:18 AM	RD	DPD
Turbidity:	1 NTU	1 - 2 NTU	1/5/26	9:18 AM	RD	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor