



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N - 1

Lab# 435

Customer

Facility Name: SRU ARC
Address: 101 Stadium Dr.
Slippery Rock, PA 16057
Matrix: Recreational Water
Source Type: Pool

Sample Collection

Date: 2/16/26
Time: 1:40 PM
Method: Grab

Sample Final Analysis

Date: 2/18/26
Time: 12:30 PM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	2/17/26	12:00 PM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	2/17/26	12:00 PM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	2/16/26	5:08 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	2/16/26	1:40 PM	BH	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	2/16/26	1:40 PM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	2/16/26	1:40 PM	BH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor