



Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 2

Lab# 2226

Customer

American Pools Management
3261 Babcock Blvd.
Pittsburgh, PA 15237

Sample Collection

Facility Name: *Glencannon*

Date: *8/5/25*

Time: *12:40 PM*

Address: *207 Driftwood Road*
Canonsburg, PA 15317

Method: *Grab*

Sample Final Analysis

Matrix: *Recreational Water*

Date: *8/8/25*

Time: *8:30 AM*

Source Type: *Wading Pool*

Analyst: *AS*

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|----------------------------|----------------|------------------------|-----------------------------|---------|----------------|---------------|
| Escherichia Coli: | Absent | Absent | 8/6/25 | 2:00 PM | AH | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 8/6/25 | 2:00 PM | AH | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 8/5/25 | 5:40 PM | AS | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|-----------------------|----------------|------------------------|------------------|----------|----------------|---------------|
| pH: | 7.4 SU | 7.2 - 7.8 SU | 8/5/25 | 12:40 PM | AF | DPD |
| Chlorine: | 2.0 mg/l | 1.0 - 5.0 mg/l | 8/5/25 | 12:40 PM | AF | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 8/5/25 | 12:40 PM | AF | Visual |

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor



Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 2

Lab# 2226

Customer

American Pools Management
3261 Babcock Blvd.
Pittsburgh, PA 15237

Sample Collection

Facility Name: Glencannon

Date: 8/5/25

Time: 12:40 PM

Address: 207 Driftwood Road
Canonsburg, PA 15317

Method: Grab

Sample Final Analysis

Matrix: Recreational Water

Date: 8/8/25

Time: 8:30 AM

Source Type: Wading Pool

Analyst: AS

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|-----------------------|----------|-----------------|----------------------|---------|---------|----------|
| Escherichia Coli: | Absent | Absent | 8/6/25 | 2:00 PM | AH | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 8/6/25 | 2:00 PM | AH | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 8/5/25 | 5:40 PM | AS | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|----------------|----------|-----------------|-----------|----------|---------|--------|
| pH: | 7.4 SU | 7.2 - 7.8 SU | 8/5/25 | 12:40 PM | AF | DPD |
| Chlorine: | 2.0 mg/l | 1.0 - 5.0 mg/l | 8/5/25 | 12:40 PM | AF | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 8/5/25 | 12:40 PM | AF | Visual |

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor