



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**W-1**

**Lab# 502**

**Customer**

Facility Name: Hampton by Hilton

Address: 202 Fairview Dr.  
Monaca, PA 15061

Matrix: Recreational Water

Source Type: Pool

**Sample Collection**

Date: 11/19/25

Time: 3:00 PM

Method: Grab

**Sample Final Analysis**

Date: 11/21/25

Time: 4:30 PM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	11/19/25	5:55 PM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	11/19/25	5:55 PM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	11/19/25	5:40 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.0 SU	7.2 - 7.8 SU	11/19/25	3:00 PM	VH	DPD
Chlorine:	10.0 mg/l	1.0 - 5.0 mg/l	11/19/25	3:00 PM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	11/19/25	3:00 PM	VH	Visual

**Sample comments**

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)