



**Dreams Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**PPS**

**Lab# 058**

**Customer**

**Facility Name:** Colfax Elementary

**Address:** 2332 Beechwood Blvd.  
Pittsburgh, PA 15217

**Matrix:** Recreational Water

**Source Type:** Pool Deep

**Sample Collection**

**Date:** 12/15/25

**Time:** 9:46 AM

**Method:** Grab

**Sample Final Analysis**

**Date:** 12/18/25

**Time:** 11:30 AM

**Analyst:** AS

Accredited Analysis	Results	Rating	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	A	12/16/25	11:00 AM	AS	SM 9222G
Total coliforms:	0/100mls	A	12/16/25	11:00 AM	AS	SM 9222B
Standard plate count:	20/ml	B	12/15/25	5:40 PM	AS	SM 9215B

Field Analysis	Results	Rating	Date/Time		Analyst	Method
pH:	7.6 SU	A	12/15/25	9:46 AM	MM	DPD
Chlorine:	3.0 mg/l	A	12/15/25	9:46 AM	MM	DPD
Turbidity:	1 NTU	A	12/15/25	9:46 AM	MM	Visual

**Sample comments**

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)