

## Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

S-11

Lab# 2424

**Customer** 

Facility Name: Quail Run Condo Outdoor

Address:

199 Quail Run Rd. Venetia, PA 15367

Matrix:

Recreational Water

Source Type: Pool

Sample Collection

Date: Time: 8/6/25 10:45 AM

Method: Grab

Sample Final Analysis

Date: Time: 8/8/25 2:00 PM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/6/25	4:50 PM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/6/25	4:50 PM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	8/6/25	3:40 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit		Date/Time	Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	8/6/25	10:45 AM	CW	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	8/6/25	10:45 AM	CW	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/6/25	10:45 AM	CW	Visual

## Sample comments

( When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor



## Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

S-11

Lab# 2424

**Customer** 

Facility Name: Quail Run Condo Outdoor

Address:

199 Quail Run Rd. Venetia, PA 15367

Matrix:

Recreational Water

Source Type: Pool

Sample Collection

Date: Time: 8/6/25 10:45 AM

Method: Grab

Sample Final Analysis

Date: Time: 8/8/25 2:00 PM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/6/25	4:50 PM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/6/25	4:50 PM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	8/6/25	3:40 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit		Date/Time	Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	8/6/25	10:45 AM	CW	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	8/6/25	10:45 AM	CW	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/6/25	10:45 AM	CW	Visual

## Sample comments

( When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor