

Dream Pools And Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

APM 1

Lab# 2083

Customer American Pools Management

3261 Babcock Blvd. Pittsburgh, PA 15237

Facility Name: Cascade Townhomes Sample Collection
Date: 8/26

Facility Name: Cascade Townhomes Date: 8/26/25
Time: 9:13 AM
Address: 100 East West Drive Method: Grab

Pittsburgh, PA 15237

Matrix: Recreational Water Sample Final Analysis

Date: 8/29/25

Source Type: Pool Time: 10:30 AM
Analyst: AS

Accredited Analysis Results Reporting limit **Analyst** Method **Incubation Date/Time** Escherichia Coli: Absent Absent 8/27/25 12:00 PM AS SM 9222G Total coliforms: 2/100mls 0/100mls 8/27/25 12:00 PM AS SM 9222B AS Standard plate count: 200/ml 200/ml 8/26/25 6:00 PM SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
рН:	8.0 SU	7.2 - 7.8 SU	8/26/25	9:13 AM	MM	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	8/26/25	9:13 AM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/26/25	9:13 AM	MM	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

andre Smith