



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

W-12

Lab# 364

Customer

Facility Name: YMCA - Sewickley
Address: 625 Blackburn Road
Sewickley, PA 15143

Matrix: Recreational Water

Source Type: Small Pool

Sample Collection

Date: 8/19/25
Time: 12:30 PM
Method: Grab

Sample Final Analysis


Date: 8/22/25
Time: 9:00 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/20/25	9:20 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/20/25	9:20 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	8/19/25	3:30 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	8/19/25	12:30 PM	VH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	8/19/25	12:30 PM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/19/25	12:30 PM	VH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)


Andrea Smith, Lead Supervisor