



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

W-11

Lab# 068

Customer

Facility Name: Cornell High School
Address: 1099 Maple Street
Coraopolis, PA 15108

Matrix: Recreational Water

Source Type: Deep End

Sample Collection

Date: 6/24/25
Time: 12:30 PM
Method: Grab

Sample Final Analysis

Date: 6/27/25
Time: 9:20 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/25/25	9:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/25/25	9:00 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/24/25	3:10 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.0 SU	7.2 - 7.8 SU	6/24/25	12:30 PM	VH	DPD
Chlorine:	10.0 mg/l	1.0 - 5.0 mg/l	6/24/25	12:30 PM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/24/25	12:30 PM	VH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

W-11

Lab# 068

Customer

Facility Name: Cornell High School
Address: 1099 Maple Street
Coraopolis, PA 15108

Matrix: Recreational Water

Source Type: Deep End

Sample Collection

Date: 6/24/25
Time: 12:30 PM
Method: Grab

Sample Final Analysis

Date: 6/27/25
Time: 9:20 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/25/25	9:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/25/25	9:00 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/24/25	3:10 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.0 SU	7.2 - 7.8 SU	6/24/25	12:30 PM	VH	DPD
Chlorine:	10.0 mg/l	1.0 - 5.0 mg/l	6/24/25	12:30 PM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/24/25	12:30 PM	VH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor