Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 2

Lab# 2189

Customer

American Pools Management
3261 Babcock Blvd.
Pittsburgh, PA 15237

		Sample Collection	
Facility Name:	*Forest Glen*	*Date:*	*7/8/25*
		Time:	11:30 AM
Address:	*1514 Forest Green Dr.*	*Method:*	*Grab*
	Moon, PA 15108		
		Sample Final Analysis	
Matrix:	*Recreational Water*	*Date:*	*7/11/25*
		Time:	*9:00 AM*
Source Type:	*Pool*	*Analyst:*	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/9/25	9:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/9/25	9:00 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	7/8/25	3:28 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	7/8/25	11:30 AM	VH	DPD
Chlorine:	10.0 mg/l	1.0 - 5.0 mg/l	7/8/25	11:30 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/8/25	11:30 AM	VH	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor

Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 2

Lab# 2189

Customer

American Pools Management
3261 Babcock Blvd.
Pittsburgh, PA 15237

Facility Name: *Forest Glen*

Address: *1514 Forest Green Dr.*
Moon, PA 15108

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Collection
Date: *7/8/25*
Time: 11:30 AM
Method: Grab

Sample Final Analysis
Date: *7/11/25*
Time: 9:00 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/9/25	9:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/9/25	9:00 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	7/8/25	3:28 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	7/8/25	11:30 AM	VH	DPD
Chlorine:	10.0 mg/l	1.0 - 5.0 mg/l	7/8/25	11:30 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/8/25	11:30 AM	VH	Visual

Sample comments

Andre Smith (signature)

(When exceeding reporting limit pool or spa is unfit)

_____
Andre Smith, Lead Supervisor