



Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661-7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 1

Lab# 2056

Customer American Pools Management
3261 Babcock Blvd.
Pittsburgh, PA 15237

Facility Name: Brentwood Borough Pool

Sample Collection

Date: 7/14/25

Address: Park Dr.
Pittsburgh, PA 15227

Time: 12:57 PM

Method: Grab

Matrix: Recreational Water

Sample Final Analysis

Date: 7/17/25

Source Type: Deep End

Time: 8:30 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	7/15/25	10:15 AM	AH SM 9222G
Total coliforms:	0/100mls	2/100mls	7/15/25	10:15 AM	AH SM 9222B
Standard plate count:	0/ml	200/ml	7/14/25	5:00 PM	AH SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	3.0 SU	7.2 - 7.8 SU	7/14/25	12:57 PM	SL DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	7/14/25	12:57 PM	SL DPD
Turbidity:	1 NTU	1 - 2 NTU	7/14/25	12:57 PM	SL Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

A handwritten signature in black ink that reads "Andre Smith".

Andre Smith, Lead Supervisor



Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661-7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 1

Lab# 2056

Customer American Pools Management
3261 Babcock Blvd.
Pittsburgh, PA 15237

Facility Name: Brentwood Borough Pool

Sample Collection

Date: 7/14/25

Address: Park Dr.
Pittsburgh, PA 15227

Time: 12:57 PM

Method: Grab

Matrix: Recreational Water

Sample Final Analysis

Date: 7/17/25

Source Type: Deep End

Time: 8:30 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	7/15/25	10:15 AM	AH SM 9222G
Total coliforms:	0/100mls	2/100mls	7/15/25	10:15 AM	AH SM 9222B
Standard plate count:	0/ml	200/ml	7/14/25	5:00 PM	AH SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	3.0 SU	7.2 - 7.8 SU	7/14/25	12:57 PM	SL DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	7/14/25	12:57 PM	SL DPD
Turbidity:	1 NTU	1 - 2 NTU	7/14/25	12:57 PM	SL Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

A handwritten signature in black ink that reads "Andre Smith".

Andre Smith, Lead Supervisor