



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**C-11**

**Lab# 2131**

**Customer**

**Facility Name:** Cork Factory  
**Address:** 2349 Rail Road St.  
Pittsburgh, PA 15222  
**Matrix:** Recreational Water  
**Source Type:** Pool

**Sample Collection**

**Date:** 7/22/25  
**Time:** 9:00 AM  
**Method:** Grab

**Sample Final Analysis**

**Date:** 7/25/25  
**Time:** 10:00 AM  
**Analyst:** AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/23/25	11:00 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/23/25	11:00 AM	SL	SM 9222B
Standard plate count:	190/ml	200/ml	7/22/25	4:30 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	7/22/25	9:00 AM	LM	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	7/22/25	9:00 AM	LM	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/22/25	9:00 AM	LM	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**C-11**

**Lab# 2131**

**Customer**

**Facility Name:** Cork Factory  
**Address:** 2349 Rail Road St.  
Pittsburgh, PA 15222  
**Matrix:** Recreational Water  
**Source Type:** Pool

**Sample Collection**

**Date:** 7/22/25  
**Time:** 9:00 AM  
**Method:** Grab

**Sample Final Analysis**

**Date:** 7/25/25  
**Time:** 10:00 AM  
**Analyst:** AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/23/25	11:00 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/23/25	11:00 AM	SL	SM 9222B
Standard plate count:	190/ml	200/ml	7/22/25	4:30 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	7/22/25	9:00 AM	LM	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	7/22/25	9:00 AM	LM	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/22/25	9:00 AM	LM	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor