



Lab ID No. 02-04041

Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

NCS**Lab# 092****Customer**

Facility Name: Doubletree Hotel
Address: 101 Doubletree Dr.
Pittsburgh, PA 15205

Matrix: Recreational Water

Source Type: Spa

Sample Collection

Date: 2/11/25
Time: 2:04 PM
Method: Grab

Sample Final Analysis

Date: 2/14/25
Time: 9:30 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	2/12/25	10:10 AM	PS	SM 9222G
Total coliforms:	0/100mls	2/100mls	2/12/25	10:10 AM	PS	SM 9222B
Standard plate count:	0/ml	200/ml	2/11/25	4:50 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	2/11/25	2:04 PM	JC	DPD
Chlorine:	10.0 mg/l	1.0 - 5.0 mg/l	2/11/25	2:04 PM	JC	DPD
Turbidity:	1 NTU	1 - 2 NTU	2/11/25	2:04 PM	JC	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Lab ID No. 02-04041

Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

NCS**Lab# 092****Customer**

Facility Name: Doubletree Hotel
Address: 101 Doubletree Dr.
Pittsburgh, PA 15205

Matrix: Recreational Water

Source Type: Spa

Sample Collection

Date: 2/11/25
Time: 2:04 PM
Method: Grab

Sample Final Analysis

Date: 2/14/25
Time: 9:30 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	2/12/25	10:10 AM	PS	SM 9222G
Total coliforms:	0/100mls	2/100mls	2/12/25	10:10 AM	PS	SM 9222B
Standard plate count:	0/ml	200/ml	2/11/25	4:50 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	2/11/25	2:04 PM	JC	DPD
Chlorine:	10.0 mg/l	1.0 - 5.0 mg/l	2/11/25	2:04 PM	JC	DPD
Turbidity:	1 NTU	1 - 2 NTU	2/11/25	2:04 PM	JC	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor