



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**SERVICE**

**Lab# 312**

**Customer**

Facility Name: UPMC Lemieux Sports Complex

Address: 8000 Cranberry Springs Drive  
Cranberry Township, PA 16066

Matrix: Recreational Water

Source Type: Cold Plunge

**Sample Collection**

Date: 1/0/00

Time: 12:00 AM

Method: Grab

**Sample Final Analysis**

Date: 1/0/00

Time: 12:00 AM

Analyst: 1/0/00

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	1/0/00	12:00 AM	0	SM 9222G
Total coliforms:	0/100mls	2/100mls	1/0/00	12:00 AM	0	SM 9222B
Standard plate count:	0/ml	200/ml	1/0/00	12:00 AM	0	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	0.0 SU	7.2 - 7.8 SU	1/0/00	12:00 AM	0	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	1/0/00	12:00 AM	0	DPD
Turbidity:	0 NTU	1 - 2 NTU	1/0/00	12:00 AM	0	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**SERVICE**

**Lab# 312**

**Customer**

Facility Name: UPMC Lemieux Sports Complex

Address: 8000 Cranberry Springs Drive  
Cranberry Township, PA 16066

Matrix: Recreational Water

Source Type: Cold Plunge

**Sample Collection**

Date: 1/0/00

Time: 12:00 AM

Method: Grab

**Sample Final Analysis**

Date: 1/0/00

Time: 12:00 AM

Analyst: 1/0/00

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	1/0/00	12:00 AM	0	SM 9222G
Total coliforms:	0/100mls	2/100mls	1/0/00	12:00 AM	0	SM 9222B
Standard plate count:	0/ml	200/ml	1/0/00	12:00 AM	0	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	0.0 SU	7.2 - 7.8 SU	1/0/00	12:00 AM	0	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	1/0/00	12:00 AM	0	DPD
Turbidity:	0 NTU	1 - 2 NTU	1/0/00	12:00 AM	0	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor