



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

C-2

Lab# 178

Customer

Facility Name: Hyatt Place
Address: 260 North Shore Dr.
Pittsburgh, PA 15212

Sample Collection

Date: 9/16/25
Time: 1:15 PM
Method: Grab

Sample Final Analysis

Date: 9/19/25
Time: 9:00 AM
Analyst: AS

Matrix: Recreational Water

Source Type: Pool

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	9/17/25	9:30 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	9/17/25	9:30 AM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	9/16/25	4:30 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.6 SU	7.2 - 7.8 SU	9/16/25	1:15 PM	BH	DPD
Chlorine:	10.0 mg/l	1.0 - 5.0 mg/l	9/16/25	1:15 PM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	9/16/25	1:15 PM	BH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor