



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**S-3**

**Lab# 160**

**Customer**

Facility Name: *Holiday Inn Express*

Address: *810 Highland Meadow Dr.  
Washington, PA 15301*

Matrix: *Recreational Water*

Source Type: *Spa*

**Sample Collection**

Date: *11/24/25*

Time: *10:46 AM*

Method: *Grab*

**Sample Final Analysis**

Date: *11/27/25*

Time: *10:00 AM*

Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Escherichia Coli:	Absent	Absent	11/25/25 9:30 AM	AS	SM 9222G
-------------------	--------	--------	------------------	----	----------

Total coliforms:	0/100mls	2/100mls	11/25/25 9:30 AM	AS	SM 9222B
------------------	----------	----------	------------------	----	----------

Standard plate count:	0/ml	200/ml	11/24/25 4:45 PM	AS	SM 9215B
-----------------------	------	--------	------------------	----	----------

Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Fecal Streptococcus	0/100mls	2/100mls	11/25/25 Total coliforms:	AS	SM 9230C
---------------------	----------	----------	---------------------------	----	----------

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
----------------	---------	-----------------	-----------	---------	--------

pH:	7.4 SU	7.2 - 7.8 SU	11/24/25 10:46 AM	GR	DPD
-----	--------	--------------	-------------------	----	-----

Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	11/24/25 10:46 AM	GR	DPD
-----------	----------	----------------	-------------------	----	-----

Turbidity:	1 NTU	1 - 2 NTU	11/24/25 10:46 AM	GR	Visual
------------	-------	-----------	-------------------	----	--------

**Sample comments**

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)