



**Dream Pools And Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

APM 2

Lab# 2141

**Customer** American Pools Management  
3261 Babcock Blvd.  
Pittsburgh, PA 15237

		<b><u>Sample Collection</u></b>
Facility Name:	Crane Village	Date: 8/13/25
Address:	651 Oaklynn Court Pittsburgh, PA 15220	Time: 10:30 AM Method: Grab
Matrix:	Recreational Water	<b><u>Sample Final Analysis</u></b>
Source Type:	Pool	Date: 8/15/25 Time: 4:00 PM Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	8/13/25 6:15 PM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/13/25 6:15 PM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	8/13/25 6:15 PM	AS	SM 9215B
Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	8/13/25 10:30 AM	CW	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	8/13/25 10:30 AM	CW	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/13/25 10:30 AM	CW	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools And Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

APM 2

Lab# 2141

**Customer** American Pools Management  
3261 Babcock Blvd.  
Pittsburgh, PA 15237

		<b><u>Sample Collection</u></b>
Facility Name:	Crane Village	Date: 8/13/25
Address:	651 Oaklynn Court Pittsburgh, PA 15220	Time: 10:30 AM Method: Grab
Matrix:	Recreational Water	<b><u>Sample Final Analysis</u></b>
Source Type:	Pool	Date: 8/15/25 Time: 4:00 PM Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	8/13/25 6:15 PM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/13/25 6:15 PM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	8/13/25 6:15 PM	AS	SM 9215B
Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	8/13/25 10:30 AM	CW	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	8/13/25 10:30 AM	CW	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/13/25 10:30 AM	CW	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

A handwritten signature in black ink that reads "Andre Smith".

Andre Smith, Lead Supervisor