



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**S-3**

**Lab# 047**

**Customer**

Facility Name: Chartiers Valley High School

Address: 50 Thoms Run Rd.  
Bridgeville, PA 15017

Matrix: Recreational Water

Source Type: Pool Deep

**Sample Collection**

Date: 9/2/25

Time: 12:18 PM

Method: Grab

**Sample Final Analysis**

Date: 9/5/25

Time: 10:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	9/3/25	10:00 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	9/3/25	10:00 AM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	9/2/25	3:50 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	9/2/25	12:18 PM	GR	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	9/2/25	12:18 PM	GR	DPD
Turbidity:	1 NTU	1 - 2 NTU	9/2/25	12:18 PM	GR	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor