



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-2

Lab# 331

Customer

Facility Name: West Mifflin High School.
Address: 91 Commonwealth Avenue
West Mifflin, PA 15122

Sample Collection

Date: 12/22/25
Time: 8:25 AM
Method: Grab

Sample Final Analysis

Date: 12/25/25
Time: 11:30 AM
Analyst: AS

Matrix: Recreational Water

Source Type: Pool Deep

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|-----------------------|----------|-----------------|----------------------|----------|---------|----------|
| Escherichia Coli: | Absent | Absent | 12/23/25 | 11:00 AM | JC | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 12/23/25 | 11:00 AM | JC | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 12/22/25 | 5:20 PM | AS | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|----------------|----------|-----------------|-----------|---------|---------|--------|
| pH: | 7.6 SU | 7.2 - 7.8 SU | 12/22/25 | 8:25 AM | SH | DPD |
| Chlorine: | 2.0 mg/l | 1.0 - 5.0 mg/l | 12/22/25 | 8:25 AM | SH | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 12/22/25 | 8:25 AM | SH | Visual |

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor