



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**N-15**

**Lab# 2007**

**Customer**

Facility Name: *Adams Pointe*  
  
Address: *1000 Adams Pointe Blvd.*  
*Mars, PA 16046*

**Sample Collection**

Date: *7/15/25*  
Time: *9:48 AM*  
Method: *Grab*

Matrix: *Recreational Water*

Source Type: *Central Pool*

**Sample Final Analysis**

Date: *7/18/25*  
Time: *9:30 AM*  
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/16/25	10:50 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/16/25	10:50 AM	EB	SM 9222B
Standard plate count:	570/ml	200/ml	7/15/25	4:20 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	7/15/25	9:48 AM	ZR	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	7/15/25	9:48 AM	ZR	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/15/25	9:48 AM	ZR	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**N-15**

**Lab# 2007**

**Customer**

Facility Name: *Adams Pointe*  
  
Address: *1000 Adams Pointe Blvd.*  
*Mars, PA 16046*

**Sample Collection**

Date: *7/15/25*  
Time: *9:48 AM*  
Method: *Grab*

Matrix: *Recreational Water*

Source Type: *Central Pool*

**Sample Final Analysis**

Date: *7/18/25*  
Time: *9:30 AM*  
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/16/25	10:50 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/16/25	10:50 AM	EB	SM 9222B
Standard plate count:	570/ml	200/ml	7/15/25	4:20 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	7/15/25	9:48 AM	ZR	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	7/15/25	9:48 AM	ZR	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/15/25	9:48 AM	ZR	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor