

## Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

N-17

Lab# 2347

6/5/25

Sample Final Analysis

<u>Customer</u> <u>Sample Collection</u>

Facility Name: Meadowbrook Apt Date: 6/2/25
Time: 1:15 PM
Address: 13 Meadow Brook Lane Method: Grab

Butler, PA 16001

Matrix: Recreational Water Date:

Source Type: Pool Time: 9:30 AM
Analyst: AS

**Accredited Analysis** Results Reporting limit **Incubation Date/Time Analyst** Method Escherichia Coli: Absent 6/3/25 10:00 AM AΗ SM 9222G Absent Total coliforms: 0/100mls 2/100mls 6/3/25 10:00 AM AΗ SM 9222B Standard plate count: 0/ml 200/ml 6/2/25 5:40 PM SL SM 9215B

Field Analysis	Results	Reporting limit		Date/Time	Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	6/2/25	1:15 PM	ВН	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/2/25	1:15 PM	ВН	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/2/25	1:15 PM	ВН	Visual

## Sample comments

andre Smith

( When exceeding reporting limit pool or spa is unfit)



## Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

N-17

Lab# 2347

6/5/25

Sample Final Analysis

<u>Customer</u> <u>Sample Collection</u>

Facility Name: Meadowbrook Apt Date: 6/2/25
Time: 1:15 PM
Address: 13 Meadow Brook Lane Method: Grab

Butler, PA 16001

Matrix: Recreational Water Date:

Source Type: Pool Time: 9:30 AM
Analyst: AS

**Accredited Analysis** Results Reporting limit **Incubation Date/Time Analyst** Method Escherichia Coli: Absent 6/3/25 10:00 AM AΗ SM 9222G Absent Total coliforms: 0/100mls 2/100mls 6/3/25 10:00 AM AΗ SM 9222B Standard plate count: 0/ml 200/ml 6/2/25 5:40 PM SL SM 9215B

Field Analysis	Results	Reporting limit		Date/Time	Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	6/2/25	1:15 PM	ВН	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/2/25	1:15 PM	ВН	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/2/25	1:15 PM	ВН	Visual

## Sample comments

andre Smith

( When exceeding reporting limit pool or spa is unfit)