

Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661-7665 **Laboratory Analysis Report**

Lab ID No. 02-04041

W-12

Lab# 221

Sample Collection Customer

Facility Name: Masonic Village Date: 8/6/25 Time: 11:45 AM

Address: 1000 Masonic Dr. Method: Grab Sewickley, PA 15143

Sample Final Analysis Recreational Water Matrix: 8/8/25 Date:

Time: 2:00 PM Source Type: Spa Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/6/25	4:50 PM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/6/25	4:50 PM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	8/6/25	3:40 PM	AS	SM 9215B
Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Fecal Streptococcus	1/100mls	2/100mls	8/6/25	4:50 PM	AS	SM 9230C

Field Analysis	Results	Reporting limit		Date/Time	Analyst	Method
рН:	7.4 SU	7.2 - 7.8 SU	8/6/25	11:45 AM	VH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	8/6/25	11:45 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/6/25	11:45 AM	VH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor



Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661-7665 **Laboratory Analysis Report**

Lab ID No. 02-04041

W-12

Lab# 221

Sample Collection Customer

Facility Name: Masonic Village Date: 8/6/25 Time: 11:45 AM

Address: 1000 Masonic Dr. Method: Grab Sewickley, PA 15143

Sample Final Analysis Recreational Water Matrix: 8/8/25 Date:

Time: 2:00 PM Source Type: Spa Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/6/25	4:50 PM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/6/25	4:50 PM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	8/6/25	3:40 PM	AS	SM 9215B
Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Fecal Streptococcus	1/100mls	2/100mls	8/6/25	4:50 PM	AS	SM 9230C

Field Analysis	Results	Reporting limit		Date/Time	Analyst	Method
рН:	7.4 SU	7.2 - 7.8 SU	8/6/25	11:45 AM	VH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	8/6/25	11:45 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/6/25	11:45 AM	VH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor