



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-2

Lab# 073

Customer

Facility Name: Courtyard by Marriott
Address: 401 West Waterfront Dr.
West Homestead, PA 15120

Sample Collection

Date: 12/8/25
Time: 7:30 AM
Method: Grab

Matrix: Recreational Water

Source Type: Pool

Sample Final Analysis

Date: 12/11/25
Time: 10:30 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	12/9/25	10:10 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/9/25	10:10 AM	JC	SM 9222B
Standard plate count:	150/ml	200/ml	12/8/25	5:00 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.6 SU	7.2 - 7.8 SU	12/8/25	7:30 AM	SH	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	12/8/25	7:30 AM	SH	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/8/25	7:30 AM	SH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor