

## Dream Pools And Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

**APM 1** 

Lab# 2060

<u>Customer</u> American Pools Management

3261 Babcock Blvd. Pittsburgh, PA 15237

Facility Name: Brightwood Plaza Apts

Address: 4940 Brightwood Plaza

Bethel Park, PA 15102

Matrix: Recreational Water

Source Type: Pool

Sample Collection

 Date:
 7/22/25

 Time:
 1:30 PM

 Method:
 Grab

Sample Final Analysis

 Date:
 7/25/25

 Time:
 10:00 AM

 Analyst:
 AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/23/25	10:00 AM	АН	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/23/25	10:00 AM	АН	SM 9222B
Standard plate count:	0/ml	200/ml	7/22/25	3:40 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	7/22/25	1:30 PM	CW	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/22/25	1:30 PM	CW	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/22/25	1:30 PM	CW	Visual

## Sample comments

( When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor



## Dream Pools And Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

**APM 1** 

Lab# 2060

<u>Customer</u> American Pools Management

3261 Babcock Blvd. Pittsburgh, PA 15237

Facility Name: Brightwood Plaza Apts

Address: 4940 Brightwood Plaza

Bethel Park, PA 15102

Matrix: Recreational Water

Source Type: Pool

Sample Collection

 Date:
 7/22/25

 Time:
 1:30 PM

 Method:
 Grab

Sample Final Analysis

 Date:
 7/25/25

 Time:
 10:00 AM

 Analyst:
 AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/23/25	10:00 AM	АН	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/23/25	10:00 AM	АН	SM 9222B
Standard plate count:	0/ml	200/ml	7/22/25	3:40 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	7/22/25	1:30 PM	CW	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/22/25	1:30 PM	CW	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/22/25	1:30 PM	CW	Visual

## Sample comments

( When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor