



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**W-13**

**Lab# 181**

**Customer**

Facility Name: Hyatt Regency Airport

Address: 1111 Airport Boulevard  
Pittsburgh, PA 15231

Matrix: Recreational Water

Source Type: Pool

**Sample Collection**

Date: 6/24/25

Time: 12:26 PM

Method: Grab

**Sample Final Analysis**

Date: 6/27/25

Time: 9:20 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	6/25/25	9:30 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/25/25	9:30 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	6/24/25	3:59 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	6/24/25	12:26 PM	AH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/24/25	12:26 PM	AH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/24/25	12:26 PM	AH	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**W-13**

**Lab# 181**

**Customer**

Facility Name: Hyatt Regency Airport

Address: 1111 Airport Boulevard  
Pittsburgh, PA 15231

Matrix: Recreational Water

Source Type: Pool

**Sample Collection**

Date: 6/24/25

Time: 12:26 PM

Method: Grab

**Sample Final Analysis**

Date: 6/27/25

Time: 9:20 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	6/25/25	9:30 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/25/25	9:30 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	6/24/25	3:59 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	6/24/25	12:26 PM	AH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/24/25	12:26 PM	AH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/24/25	12:26 PM	AH	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor