



**Dreams Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206** **PPS**  
**(412) 661- 7665**  
**Laboratory Analysis Report Lab# 019**

Lab ID No. 02-04041

| <u>Customer</u>       |  | <u>Sample Collection</u>     |                      |          |             |
|-----------------------|--|------------------------------|----------------------|----------|-------------|
| Facility Name:        | Baxter Building                          | Date:                        | 11/24/25             |          |             |
| Address:              | 925 Brushton Ave<br>Pittsburgh, PA 15208 | Time:                        | 9:45 AM              |          |             |
| Matrix:               |  | <u>Sample Final Analysis</u> |                      |          |             |
| Source Type:          | Recreational Water                       | Date:                        | 11/27/25             |          |             |
|                       | Pool Shallow                             | Time:                        | 11:00 AM             |          |             |
|                       |  | Analyst:                     | AS                   |          |             |
| Accredited Analysis   | Results                                  | Rating                       | Incubation Date/Time | Analyst  | Method      |
| Escherichia Coli:     | Absent                                   | A                            | 11/25/25             | 10:30 AM | AS SM 9222G |
| Total coliforms:      | 0/100mls                                 | A                            | 11/25/25             | 10:30 AM | AS SM 9222B |
| Standard plate count: | 0/ml                                     | A                            | 11/24/25             | 4:45 PM  | AS SM 9215B |
| Field Analysis        | Results                                  | Rating                       | Date/Time            | Analyst  | Method      |
| pH:                   | 8.0 SU                                   | E                            | 11/24/25             | 9:45 AM  | MM DPD      |
| Chlorine:             | 2.0 mg/l                                 | B                            | 11/24/25             | 9:45 AM  | MM DPD      |
| Turbidity:            | 1 NTU                                    | A                            | 11/24/25             | 9:45 AM  | MM Visual   |

Sample comments

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)