



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-12

Lab# 2456

Customer

Facility Name: Sandcastles Water Park

Address: 1000 Sandcastle Drive
Homestead, PA 15120

Matrix: Recreational Water

Source Type: Dragon's Den

Sample Collection

Date: 6/9/25

Time: 9:00 AM

Method: Grab

Sample Final Analysis

Date: 6/12/25

Time: 9:30 AM

Analyst: AS

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|-----------------------|----------|-----------------|----------------------|----------|---------|----------|
| Escherichia Coli: | Absent | Absent | 6/10/25 | 11:15 AM | EB | SM 9222G |
| Total coliforms: | 2/100mls | 2/100mls | 6/10/25 | 11:15 AM | EB | SM 9222B |
| Standard plate count: | 5700/ml | 200/ml | 6/9/25 | 5:40 PM | SL | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|----------------|----------|-----------------|-----------|---------|---------|--------|
| pH: | 7.0 SU | 7.2 - 7.8 SU | 6/9/25 | 9:00 AM | DW | DPD |
| Chlorine: | 0.0 mg/l | 1.0 - 5.0 mg/l | 6/9/25 | 9:00 AM | DW | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 6/9/25 | 9:00 AM | DW | Visual |

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-12

Lab# 2456

Customer

Facility Name: Sandcastles Water Park

Address: 1000 Sandcastle Drive
Homestead, PA 15120

Matrix: Recreational Water

Source Type: Dragon's Den

Sample Collection

Date: 6/9/25

Time: 9:00 AM

Method: Grab

Sample Final Analysis

Date: 6/12/25

Time: 9:30 AM

Analyst: AS

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|-----------------------|----------|-----------------|----------------------|----------|---------|----------|
| Escherichia Coli: | Absent | Absent | 6/10/25 | 11:15 AM | EB | SM 9222G |
| Total coliforms: | 2/100mls | 2/100mls | 6/10/25 | 11:15 AM | EB | SM 9222B |
| Standard plate count: | 5700/ml | 200/ml | 6/9/25 | 5:40 PM | SL | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|----------------|----------|-----------------|-----------|---------|---------|--------|
| pH: | 7.0 SU | 7.2 - 7.8 SU | 6/9/25 | 9:00 AM | DW | DPD |
| Chlorine: | 0.0 mg/l | 1.0 - 5.0 mg/l | 6/9/25 | 9:00 AM | DW | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 6/9/25 | 9:00 AM | DW | Visual |

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor