



Dreams Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

PPS

Lab# 112

Customer

Facility Name: Greenfield Elementary

Address: 1 Alger St.
Pittsburgh, PA 15207

Matrix: Recreational Water

Source Type: Shallow End

Sample Collection

Date: 12/23/25

Time: 11:11 AM

Method: Grab

Sample Final Analysis

Date: 12/26/25

Time: 12:00 PM

Analyst: AS

Accredited Analysis	Results	Rating	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	A	12/24/25	11:30 AM	AS	SM 9222G
Total coliforms:	0/100mls	A	12/24/25	11:30 AM	AS	SM 9222B
Standard plate count:	0/ml	A	12/23/25	5:30 PM	AS	SM 9215B

Field Analysis	Results	Rating	Date/Time		Analyst	Method
pH:	7.8 SU	C	12/23/25	11:11 AM	MM	DPD
Chlorine:	3.0 mg/l	A	12/23/25	11:11 AM	MM	DPD
Turbidity:	1 NTU	A	12/23/25	11:11 AM	MM	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)