

Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

E - 10

Lab# 202

Sample Final Analysis

<u>Customer</u> Sample Collection

Facility Name: L.A. Fitness Greensburg Date: 7/1/25
Time: 9:31 AM

Address: 3000 Lincoln Place Method: Grab

Greensburg, PA 15601

Matrix: Recreational Water Date: 7/4/25
Time: 9:30 AM

Source Type: Pool Time: 9:30 AM
Analyst: AS

Accredited Analysis Results Reporting limit **Analyst** Method **Incubation Date/Time** Escherichia Coli: 7/2/25 10:00 AM SM 9222G Absent Absent EΒ Total coliforms: 0/100mls 2/100mls 7/2/25 10:00 AM ΕB SM 9222B 7/1/25 Standard plate count: 0/ml 200/ml 4:00 PM EB SM 9215B

Field Analysis	Results	Reporting limit		Date/Time	Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	7/1/25	9:31 AM	JC	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/1/25	9:31 AM	JC	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/1/25	9:31 AM	JC	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor



Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

E - 10

Lab# 202

Sample Final Analysis

<u>Customer</u> Sample Collection

Facility Name: L.A. Fitness Greensburg Date: 7/1/25
Time: 9:31 AM

Address: 3000 Lincoln Place Method: Grab

Greensburg, PA 15601

Matrix: Recreational Water Date: 7/4/25
Time: 9:30 AM

Source Type: Pool Time: 9:30 AM
Analyst: AS

Accredited Analysis Results Reporting limit **Analyst** Method **Incubation Date/Time** Escherichia Coli: 7/2/25 10:00 AM SM 9222G Absent Absent EΒ Total coliforms: 0/100mls 2/100mls 7/2/25 10:00 AM ΕB SM 9222B 7/1/25 Standard plate count: 0/ml 200/ml 4:00 PM EB SM 9215B

Field Analysis	Results	Reporting limit		Date/Time	Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	7/1/25	9:31 AM	JC	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/1/25	9:31 AM	JC	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/1/25	9:31 AM	JC	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor