



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**N-16**

**Lab# 2531**

**Customer**

Facility Name: *Treesdale Comm. Pool*

Address: *1 Treesdale Cmns  
Gibsonia, PA 15044*

Matrix: *Recreational Water*

Source Type: *Baby Pool*

**Sample Collection**

Date: *8/25/25*

Time: *1:24 PM*

Method: *Grab*

**Sample Final Analysis**

Date: *8/28/25*

Time: *9:00 AM*

Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/26/25	9:20 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/26/25	9:20 AM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	8/25/25	3:50 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	8/25/25	1:24 PM	GR	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	8/25/25	1:24 PM	GR	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/25/25	1:24 PM	GR	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor